

UK Declaration of Conformity for BOA-CVE C/CS/W/IMS/EKB/IMS EKB

Herewith we,

KSB SE & Co. KGaA
Johann-Klein-Straße 9
67227 Frankenthal (Germany)

declare that the product:

BOA-CVE C	PN 6, 16	DN 15-200
BOA-CVE CS	PN 6/10/16	DN 20-200
BOA-CVE W	PN 6, 16	DN 15-200
BOA-CVE IMS	PN 16	DN 15-200
BOA-CVE EKB	PN 10/16	DN 15-200
BOA-CVE IMS EKB	PN 16	DN 15-200

satisfies the safety requirements of the Pressure Equipment (Safety) Regulations 2016.

Applied harmonised European standards:

Globe valves EN 19, EN 12516, EN 12266-1, EN 13789, EN 1092-2

Other standards/codes:

DIN 3840

Suitable for:

Fluids in Group 2

Conformity assessment procedure:

Module H

Name and address of the UK-approved body:

TÜV SÜD BABT Unlimited
 Octagon House
 Concorde Way, Segensworth North
 Fareham, Hampshire
 PO15 5RL (United Kingdom)

Identification number of the UK-approved body:

0168

Other applicable regulations:

Electromagnetic compatibility: Electromagnetic Compatibility Regulations 2016
 Low-voltage Directive: Electrical Equipment (Safety) Regulations 2016

Valves $\leq$ DN 50 (PN 16), $\leq$ DN 100 (PN 10) and $\leq$ DN 150 (PN 6) comply with the Pressure Equipment (Safety) Regulations 2016, PART 1, para. 8. They must bear neither the UKCA marking nor the identification number of the UK-approved body.

The UK Declaration of Conformity was issued in/on:

Frankenthal, 19 October 2022




Rainer Michalik
 Head of Integrated Management Systems

Marco Kroth
 Head of BU GGC Product Development