

**EU Declaration of Conformity for BOA-H/HE, NORI 40, NORI 160, NORI 320, NORI 500,
ZJSVA/ZXSVA, RGS**

Herewith we,

KSB SE & Co. KGaA
Bahnhofplatz 1
91257 Pegnitz
Registered office: Frankenthal (Pfalz)
Germany

declare that the product:

Globe valves

BOA-H/HE	PN 25/40	DN 10 - 350
NORI 40	PN 25/40	DN 10 - 400
NORI 160	PN 63 - 160	DN 10 - 200
NORI 320 (ZXLf/ZXSf)	PN 250/320	DN 65 - 200
NORI 320 (ZXSv)	PN 250/320	DN 10 - 50
NORI 500 (ZXSv)	PN 250 - 500	DN 10 - 65
NORI 500 (ZXLr/ZXSR)	PN 250 - 500	DN 10 - 50

Start and stop control valves

ZJSVA/ZXSVA/ZYSVA/ZYSVA-FSS Pmax. = 600 bar DN 65/60 - 250/125

Lift check valves / strainers

NORI 40	PN 25/40	DN 10 - 300
NORI 160	PN 63 - 160	DN 10 - 200
NORI 320 (RXl/RXs)	PN 250/320	DN 65 - 200
NORI 500 (RXlR/RXSR)	PN 250 - 500	DN 10 - 50
RGS/RGS-FSS	PN 250 - 500	DN 10 - 50

satisfies the safety requirements laid down in the European Pressure Equipment Directive 2014/68/EU.

Codes applied:

AD 2000 code

Suitable for:

Fluids in Groups 1 and 2

Conformity assessment procedure:

Module H


Name and address of the notified body responsible for approval and surveillance:TÜV SÜD Industrie Service GmbH
Westendstraße 199
80686 München (Germany)**Identification number of the notified body:**

0036

Valves \leq DN 25 fall under Article 4, Section 3, of the Pressure Equipment Directive 2014/68/EU. They must bear neither the CE marking nor the identification number of a notified body.

The EU Declaration of Conformity was issued in/on:

Frankenthal, 8 February 2022

Rainer Michalik
Head of Integrated Management SystemsMarco Kroth
Head of BU GGC Product Development Pegnitz